



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2156**

**Customer**

Facility Name: Dormont Borough Pool

Address: 1444 Hillsdale Avenue  
Pittsburgh, PA 15216

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 8/4/25

Time: 9:37 AM

Method: Grab

**Sample Final Analysis**

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/25	9:37 AM	CW	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	8/4/25	9:37 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	9:37 AM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2156**

**Customer**

Facility Name: *Dormont Borough Pool*

Address: *1444 Hillsdale Avenue*  
*Pittsburgh, PA 15216*

Matrix: *Recreational Water*

Source Type: *Shallow End*

**Sample Collection**

Date: *8/4/25*

Time: *9:37 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *8/7/25*

Time: *11:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/25	9:37 AM	CW	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	8/4/25	9:37 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	9:37 AM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor