

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2299

Customer

Facility Name: Jefferson Estates

Address: Woodwind Dr.

Jefferson Hills, PA 15025

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/28/25

 Time:
 1:58 AM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/31/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/29/25 10:30 AM AΗ SM 9222G Total coliforms: 0/100mls SM 9222B 2/100mls 7/29/25 10:30 AM AΗ SL Standard plate count: 200/ml 5:05 PM SM 9215B 0/ml 7/28/25

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	1:58 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:58 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:58 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

anobre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2299

Customer

Facility Name: Jefferson Estates

Address: Woodwind Dr.

Jefferson Hills, PA 15025

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/28/25

 Time:
 1:58 AM

 Method:
 Grab

Sample Final Analysis

 Date:
 7/31/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/29/25 10:30 AM AΗ SM 9222G Total coliforms: 0/100mls SM 9222B 2/100mls 7/29/25 10:30 AM AΗ SL Standard plate count: 200/ml 5:05 PM SM 9215B 0/ml 7/28/25

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	1:58 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:58 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:58 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

anobre Smith

Andre Smith, Lead Supervisor