



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 091

Customer

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 2/3/26
Time: 7:53 AM
Method: Grab

Sample Final Analysis

Date: 2/6/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	2/3/26	7:53 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/3/26	7:53 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26	7:53 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor