



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2170**

**Customer**

**Facility Name:** Edgewood Club

**Address:** 1 Pennwood Ave  
Pittsburgh, PA 15218

**Matrix:** Recreational Water

**Source Type:** Shallow End

**Sample Collection**

**Date:** 5/28/25

**Time:** 3:45 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 5/31/25

**Time:** 9:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	3:45 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	3:45 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	3:45 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2170**

**Customer**

Facility Name: Edgewood Club

Address: 1 Pennwood Ave  
Pittsburgh, PA 15218

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 5/28/25

Time: 3:45 PM

Method: Grab

**Sample Final Analysis**

Date: 5/31/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	3:45 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	3:45 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	3:45 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor