



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 387**

**Customer**

Facility Name: Residence Inn Cranberry

Address: 1308 Freedom Rd.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/9/25

Time: 10:46 AM

Method: Grab

**Sample Final Analysis**

Date: 6/12/25

Time: 9:30 AM

Analyst: #REF!

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |         |         |    |          |
|-------------------|--------|--------|---------|---------|----|----------|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 9:15 AM | EB | SM 9222G |
|-------------------|--------|--------|---------|---------|----|----------|

|                  |          |          |         |         |    |          |
|------------------|----------|----------|---------|---------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 6/10/25 | 9:15 AM | EB | SM 9222B |
|------------------|----------|----------|---------|---------|----|----------|

|                       |      |        |        |         |    |          |
|-----------------------|------|--------|--------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 6/9/25 | 2:51 PM | EB | SM 9215B |
|-----------------------|------|--------|--------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |          |    |          |
|---------------------|----------|----------|---------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 6/10/25 | 11:55 AM | AH | SM 9230C |
|---------------------|----------|----------|---------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |        |          |    |     |
|-----|--------|--------------|--------|----------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/9/25 | 10:46 AM | ZR | DPD |
|-----|--------|--------------|--------|----------|----|-----|

|           |          |                |        |          |    |     |
|-----------|----------|----------------|--------|----------|----|-----|
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 10:46 AM | ZR | DPD |
|-----------|----------|----------------|--------|----------|----|-----|

|            |       |           |        |          |    |        |
|------------|-------|-----------|--------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 10:46 AM | ZR | Visual |
|------------|-------|-----------|--------|----------|----|--------|

**Sample comments**

*Anaë Smith*

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 387**

**Customer**

Facility Name: Residence Inn Cranberry

Address: 1308 Freedom Rd.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/9/25

Time: 10:46 AM

Method: Grab

**Sample Final Analysis**

Date: 6/12/25

Time: 9:30 AM

Analyst: #REF!

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |         |         |    |          |
|-------------------|--------|--------|---------|---------|----|----------|
| Escherichia Coli: | Absent | Absent | 6/10/25 | 9:15 AM | EB | SM 9222G |
|-------------------|--------|--------|---------|---------|----|----------|

|                  |          |          |         |         |    |          |
|------------------|----------|----------|---------|---------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 6/10/25 | 9:15 AM | EB | SM 9222B |
|------------------|----------|----------|---------|---------|----|----------|

|                       |      |        |        |         |    |          |
|-----------------------|------|--------|--------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 6/9/25 | 2:51 PM | EB | SM 9215B |
|-----------------------|------|--------|--------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |          |    |          |
|---------------------|----------|----------|---------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 6/10/25 | 11:55 AM | AH | SM 9230C |
|---------------------|----------|----------|---------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |        |          |    |     |
|-----|--------|--------------|--------|----------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/9/25 | 10:46 AM | ZR | DPD |
|-----|--------|--------------|--------|----------|----|-----|

|           |          |                |        |          |    |     |
|-----------|----------|----------------|--------|----------|----|-----|
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 6/9/25 | 10:46 AM | ZR | DPD |
|-----------|----------|----------------|--------|----------|----|-----|

|            |       |           |        |          |    |        |
|------------|-------|-----------|--------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/9/25 | 10:46 AM | ZR | Visual |
|------------|-------|-----------|--------|----------|----|--------|

**Sample comments**

*Andrea Smith*

( When exceeding reporting limit pool or spa is unfit)