

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2436

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Trellis North Fayette Date: 5/28/25
Time: 11:12 AM

Address: 1500 Park Lane Drive Method: Grab

Pittsburgh, PA 15275

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/29/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.2 SU	7.2 - 7.8 SU	5/28/25	11:12 AM	АН	DPD	
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:12 AM	АН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:12 AM	АН	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2436

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Trellis North Fayette Date: 5/28/25
Time: 11:12 AM

Address: 1500 Park Lane Drive Method: Grab

Pittsburgh, PA 15275

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Time: 9:30 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/29/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.2 SU	7.2 - 7.8 SU	5/28/25	11:12 AM	АН	DPD	
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/28/25	11:12 AM	АН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	11:12 AM	АН	Visual	

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)