



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

LCP

Lab# 2403

Customer

Facility Name: *Pgh Golf Club*

Address: *5280 Northumberland St.*
Pittsburgh, PA 15217

Sample Collection

Date: *9/16/25*
Time: *9:35 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *9/19/25*
Time: *9:00 AM*
Analyst: *AS*

Source Type: *Baby Pool*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/17/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/17/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/16/25	2:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/16/25	9:35 AM	GR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	9/16/25	9:35 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/25	9:35 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor