

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2220

Customer			Sample Collection				
Facility Name:	Garden City	y Swim Club	Date:	7/15/25			
			Time:	1:05 PM			
Address:	510 Garder	n City Dr.	Method:	Grab			
	Monroeville	e, PA 15146					
			Sample Final Analysis				
Matrix:	Recreationa	al Water	Date:	7/18/25			
			Time:	9:30 AM			
Source Type:	Shallow En	d	Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst Meth			

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	АН	SM 9222B
Standard plate count:	350/ml	200/ml	7/15/25	3:28 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	1:05 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	1:05 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	1:05 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2220

Customer			Sample Collection				
Facility Name:	Garden City	y Swim Club	Date:	7/15/25			
			Time:	1:05 PM			
Address:	510 Garder	n City Dr.	Method:	Grab			
	Monroeville	e, PA 15146					
			Sample Final Analysis				
Matrix:	Recreationa	al Water	Date:	7/18/25			
			Time:	9:30 AM			
Source Type:	Shallow En	d	Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst Meth			

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	АН	SM 9222B
Standard plate count:	350/ml	200/ml	7/15/25	3:28 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25	1:05 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	1:05 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	1:05 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor