

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

J-1

S-14

Lab ID No. 02-04041

Lab# 322

Customer

Facility Name: Upper St. Clair Rec.

Address: 1551 Mayview Rd.

Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/27/25

Time: 2:08 PM Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	5/27/25	2:08 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	2:08 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	2:08 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

J-1

S-14

Lab ID No. 02-04041

Lab# 322

Customer

Facility Name: Upper St. Clair Rec.

Address: 1551 Mayview Rd.

Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/27/25

Time: 2:08 PM Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	10:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	10:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	5/27/25	2:08 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	2:08 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	2:08 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor