



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2304

Customer

Facility Name: *Kennywood Park*

Address: *4800 Kennywood Blvd.
West Mifflin, PA 15122*

Matrix: *Recreational Water*

Source Type: *PGH Plunge*

Sample Collection

Date: *6/2/25*

Time: *11:56 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/5/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	11:56 AM	DW	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/2/25	11:56 AM	DW	DPD
Turbidity:	2 NTU	1 - 2 NTU	6/2/25	11:56 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2304

Customer

Facility Name: *Kennywood Park*

Address: *4800 Kennywood Blvd.*
West Mifflin, PA 15122

Matrix: *Recreational Water*

Source Type: *PGH Plunge*

Sample Collection

Date: *6/2/25*

Time: *11:56 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/5/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/2/25	11:56 AM	DW	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/2/25	11:56 AM	DW	DPD
Turbidity:	2 NTU	1 - 2 NTU	6/2/25	11:56 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor