



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2432

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Reserve at Southpoint*

Address: *1000 Meadow Lane*
 Canonsburg PA 15317

Sample Collection

Date: *8/26/25*
Time: *1:30 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *8/29/25*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25 12:00 PM	AS	SM 9222G

Total coliforms:	0/100mls	2/100mls	8/27/25 12:00 PM	AS	SM 9222B
------------------	----------	----------	-----------------------	----	----------

Standard plate count:	0/ml	200/ml	8/26/25 5:30 PM	AS	SM 9215B
-----------------------	------	--------	----------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00 12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/26/25 1:30 PM	AF	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/26/25 1:30 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25 1:30 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor