



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

No. 15 No. 02-04041

Lab# 442

**Customer**

Facility Name: Atria Cranberry Woods

**Sample Collection**

Date: 7/29/25

Time: 10:52 AM

Method: Grab

Address: 3020 Fairport Lane  
Cranberry, PA 16066

**Sample Final Analysis**

Date: 8/1/25

Time: 9:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	EB SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	EB SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/29/25	10:52 AM	ZR DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/29/25	10:52 AM	ZR DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	10:52 AM	ZR Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anne Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

No. 15 No. 02-04041

Lab# 442

**Customer**

Facility Name: Atria Cranberry Woods

**Sample Collection**

Date: 7/29/25

Time: 10:52 AM

Method: Grab

Address: 3020 Fairport Lane  
Cranberry, PA 16066

**Sample Final Analysis**

Date: 8/1/25

Time: 9:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	EB SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	EB SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:30 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/29/25	10:52 AM	ZR DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/29/25	10:52 AM	ZR DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	10:52 AM	ZR Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anne Smith*