



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Service

Lab# 379

Customer

Facility Name: PPG Paints Arena

Sample Collection

Date: 2/26

Address: 1001 Fifth Ave
Pittsburgh, PA 15219

Time: 11:15 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 2/5/26

Source Type: Spa

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/3/26	10:00 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26	10:00 AM	SL SM 9222B
Standard plate count:	520/ml	200/ml	2/2/26	4:10 PM	SL SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/3/26	11:00 AM	JC SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.7 SU	7.2 - 7.8 SU	2/2/26	11:15 AM	AG DPD
Chlorine:	0.2 mg/l	1.0 - 5.0 mg/l	2/2/26	11:15 AM	AG DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26	11:15 AM	AG Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)