



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2242**

**Customer**

Facility Name: Hawthorne Commons  
Address: 214 Sycamore Dr.  
Seven Fields, PA 16046

**Sample Collection**

Date: 8/12/25  
Time: 11:15 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 8/15/25  
Time: 9:00 AM  
Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/13/25 11:30 AM     | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/13/25 11:30 AM     | AH      | SM 9222B |
| Standard plate count: | 200/ml   | 200/ml          | 8/12/25 5:35 PM      | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time        | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/12/25 11:15 AM | ZS      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 8/12/25 11:15 AM | ZS      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/12/25 11:15 AM | ZS      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2242**

**Customer**

**Facility Name:** Hawthorne Commons  
**Address:** 214 Sycamore Dr.  
Seven Fields, PA 16046

**Sample Collection**

**Date:** 8/12/25  
**Time:** 11:15 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 8/15/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/13/25 11:30 AM     | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/13/25 11:30 AM     | AH      | SM 9222B |
| Standard plate count: | 200/ml   | 200/ml          | 8/12/25 5:35 PM      | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time        | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/12/25 11:15 AM | ZS      | DPD    |
| Chlorine:      | 1.0 mg/l | 1.0 - 5.0 mg/l  | 8/12/25 11:15 AM | ZS      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/12/25 11:15 AM | ZS      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor