



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 348

Customer

Facility Name: Wyndham Grand
Address: 600 Commonwealth Place
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/29/25
Time: 11:35 AM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 7/30/25 10:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 10:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 4:00 PM | EB | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/30/25 10:50 AM | EB | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|------------------|----|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 7/29/25 11:35 AM | LM | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 7/29/25 11:35 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 11:35 AM | LM | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 348

Customer

Facility Name: Wyndham Grand
Address: 600 Commonwealth Place
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/29/25
Time: 11:35 AM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 7/30/25 10:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 10:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 4:00 PM | EB | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/30/25 10:50 AM | EB | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|------------------|----|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 7/29/25 11:35 AM | LM | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 7/29/25 11:35 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 11:35 AM | LM | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor