



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2318**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/5/25*  
*Time: 11:20 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/8/25*  
*Time: 8:30 AM*  
*Analyst: AS*

*Facility Name:*

*LaVale*

*Address:*

*140 Lavale Dr.*  
*Monroeville, PA 15146*

*Matrix:*

*Recreational Water*

*Source Type:*

*Pool*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	11:20 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	11:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:20 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2318**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/5/25*  
*Time: 11:20 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/8/25*  
*Time: 8:30 AM*  
*Analyst: AS*

*Facility Name:*

*LaVale*

*Address:*

*140 Lavale Dr.*  
*Monroeville, PA 15146*

*Matrix:*

*Recreational Water*

*Source Type:*

*Pool*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/6/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	10:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	4:00 PM	AS	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	8.0 SU	7.2 - 7.8 SU	8/5/25	11:20 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/5/25	11:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	11:20 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor