



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2612

Customer

Facility Name: YMCA - Mon-Valley
Address: 101 Taylor Run Road
Monongahela, Pa 15063

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 3:30 PM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	7/15/25	11:15 AM	AH	SM 9222G
Total coliforms:	50/100mls	2/100mls	7/15/25	11:15 AM	AH	SM 9222B
Standard plate count:	57100/ml	200/ml	7/14/25	5:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	3:30 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/14/25	3:30 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	3:30 PM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2612

Customer

Facility Name: YMCA - Mon-Valley
Address: 101 Taylor Run Road
Monongahela, Pa 15063

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 3:30 PM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	7/15/25	11:15 AM	AH	SM 9222G
Total coliforms:	50/100mls	2/100mls	7/15/25	11:15 AM	AH	SM 9222B
Standard plate count:	57100/ml	200/ml	7/14/25	5:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	3:30 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/14/25	3:30 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	3:30 PM	SH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor