



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 132

Customer

Facility Name: Hampton Inn - Uniontown

Address: 698 West Main Street
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/1/25

Time: 12:50 PM

Method: Grab

Sample Final Analysis

Date: 12/4/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/2/25	10:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/2/25	10:55 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/1/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/1/25	12:50 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/1/25	12:50 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/1/25	12:50 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)