



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 033**

**Customer**

Facility Name: Candlewood Suites  
Address: 20036 Rt. 19, Oak Tree Place  
Cranberry Twp., PA 16066

**Sample Collection**

Date: 7/28/25  
Time: 10:15 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 7/31/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/28/25	10:15 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	10:15 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	10:15 AM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 033**

**Customer**

Facility Name: *Candlewood Suites*  
Address: *20036 Rt. 19, Oak Tree Place*  
*Cranberry Twp., PA 16066*

**Sample Collection**

Date: *7/28/25*  
Time: *10:15 AM*  
Method: *Grab*

Matrix: *Recreational Water*  
Source Type: *Pool*

**Sample Final Analysis**

Date: *7/31/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/28/25	10:15 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/28/25	10:15 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	10:15 AM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)