



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report Lab# 045

Lab ID No. 02-04041

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Carrick High School	Date:	9/8/25		
Address:	125 Parkfield St. Pittsburgh, PA 15210	Time:	2:55 PM		
Matrix:		<u>Sample Final Analysis</u>			
Source Type:	Recreational Water	Date:	9/11/25		
	Pool Deep	Time:	10:00 AM		
		Analyst:	AS		
Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	9/9/25	9:30 AM	SL SM 9222G
Total coliforms:	0/100mls	A	9/9/25	9:30 AM	SL SM 9222B
Standard plate count:	0/ml	A	9/8/25	5:30 PM	AS SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.4 SU	A	9/8/25	2:55 PM	MM DPD
Chlorine:	4.0 mg/l	B	9/8/25	2:55 PM	MM DPD
Turbidity:	1 NTU	A	9/8/25	2:55 PM	MM Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor