



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2639**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 6/25/25*  
*Time: 1:30 PM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 6/27/25*  
*Time: 4:30 PM*  
*Analyst: AS*

*Facility Name: Village of Easton*

*Address: 6000 Beatty Dr.*  
*Irwin, PA 15642*

*Matrix: Recreational Water*

*Source Type: Pool*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/25/25	6:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	6:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	6:40 PM	AS	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	6/25/25	1:30 PM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/25/25	1:30 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	1:30 PM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2639**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Village of Easton*

*Date: 6/25/25*

*Address: 6000 Beatty Dr.*  
*Irwin, PA 15642*

*Time: 1:30 PM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/27/25*

*Source Type: Pool*

*Time: 4:30 PM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/25/25	6:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	6:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	6:40 PM	AS	SM 9215B
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	6/25/25	1:30 PM	ZR	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/25/25	1:30 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	1:30 PM	ZR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor