



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2229**

**Customer**

Facility Name: *Glen's Pool*  
  
Address: *100 Inverness Dr.*  
*Pittsburgh, PA 15237*

**Sample Collection**

Date: *7/30/25*  
Time: *12:55 PM*  
Method: *Grab*

Matrix: *Recreational Water*

**Sample Final Analysis**

Date: *8/1/25*  
Time: *3:30 PM*  
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	4:55 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	4:55 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/30/25	12:55 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/30/25	12:55 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	12:55 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2229**

**Customer**

Facility Name: *Glen's Pool*  
  
Address: *100 Inverness Dr.*  
*Pittsburgh, PA 15237*

**Sample Collection**

Date: *7/30/25*  
Time: *12:55 PM*  
Method: *Grab*

Matrix: *Recreational Water*

**Sample Final Analysis**

Date: *8/1/25*  
Time: *3:30 PM*  
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	4:55 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	4:55 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/30/25	12:55 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/30/25	12:55 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	12:55 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor