



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 229

Customer

Facility Name: *Montour High School*
Address: *223 Clever Rd.*
Mc Kees Rocks, PA 15136

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *10/20/25*
Time: *8:21 AM*
Method: *Grab*

Sample Final Analysis

Date: *10/23/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/21/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/21/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/20/25	5:04 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	10/20/25	8:21 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/20/25	8:21 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/20/25	8:21 AM	AMH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor