



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 112**

**Customer**

Facility Name: Greenfield Elementary

Address: 1 Alger St.  
Pittsburgh, PA 15207

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 1/12/26

Time: 12:46 PM

Method: Grab

**Sample Final Analysis**

Date: 1/15/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	1/13/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	1/13/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	A	1/12/26	4:45 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	1/12/26	12:46 PM	MM	DPD
Chlorine:	1.0 mg/l	D	1/12/26	12:46 PM	MM	DPD
Turbidity:	1 NTU	A	1/12/26	12:46 PM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)