



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 126

Customer

Facility Name: Hampton Inn - Butler

Address: 610 Butler Crossing
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/15/25

Time: 3:45 PM

Method: Grab

Sample Final Analysis

Date: 12/18/25

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/16/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/16/25	11:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/15/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 /SU	7.2 - 7.8 SU	12/15/25	3:45 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/15/25	3:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/15/25	3:45 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor