



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2144**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Crossroad Tower*  
  
*Address:*      *200 Sophia Drive*  
*Pittsburgh, PA 15230*

*Date:*      6/23/25  
*Time:*      2:10 PM  
*Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
  
*Source Type:*      *Pool*

*Date:*      6/26/25  
*Time:*      9:00 AM  
*Analyst:*      AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	2:10 PM	DW	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/23/25	2:10 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	2:10 PM	DW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2144**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Crossroad Tower*  
  
*Address:*      *200 Sophia Drive*  
*Pittsburgh, PA 15230*

*Date:*      6/23/25  
*Time:*      2:10 PM  
*Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
  
*Source Type:*      *Pool*

*Date:*      6/26/25  
*Time:*      9:00 AM  
*Analyst:*      AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25      11:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25      11:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25      6:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25      2:10 PM	DW	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/23/25      2:10 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25      2:10 PM	DW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor