



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2316

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name:

Laurel Village

Address:

1000 Penn Center Blvd.
Pittsburgh, PA 15235

Matrix:

Recreational Water

Source Type:

Deep End

Sample Collection

Date: 7/14/25
Time: 8:55 AM
Method: Grab

Sample Final Analysis

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	8:55 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/14/25	8:55 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	8:55 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2316

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Laurel Village*

Address: *1000 Penn Center Blvd.*
Pittsburgh, PA 15235

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *7/14/25*
Time: *8:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/17/25*
Time: *8:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:04 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/25	8:55 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/14/25	8:55 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	8:55 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor