



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 219

Customer

Facility Name: Marriott Airport
Address: 777 Aten Road
Coraopolis, PA 15108
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/12/25
Time: 10:46 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	10:46 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	10:46 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:46 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andrea Smith". The signature is fluid and cursive, with "Andrea" on the top line and "Smith" on the bottom line.



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 219

Customer

Facility Name: Marriott Airport
Address: 777 Aten Road
Coraopolis, PA 15108
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/12/25
Time: 10:46 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	10:46 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	10:46 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:46 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andrea Smith". The signature is fluid and cursive, with "Andrea" on the top line and "Smith" on the bottom line.