



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 332**

**Customer**

**Facility Name:** West Mifflin High School  
**Address:** 91 Commonwealth Avenue  
West Mifflin, PA 15122

**Matrix:** Recreational Water

**Source Type:** Pool Shallow

**Sample Collection**

**Date:** 12/29/25  
**Time:** 8:30 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 1/1/26  
**Time:** 11:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	12/29/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/29/25	8:30 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/29/25	8:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/29/25	8:30 AM	SH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)