1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2429

Customer

Facility Name: *Ream*

Address: *321 Merrimac St.*
Pittsburgh, PA 15211

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *7/1/25*
Time: 11:48 AM
Method: *Grab*

Sample Final Analysis

Date: *7/4/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	11:48 AM	WB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:48 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:48 AM	WB	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2429

Customer

Facility Name: *Ream*

Address: *321 Merrimac St.*
Pittsburgh, PA 15211

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *7/1/25*
Time: 11:48 AM
Method: *Grab*

Sample Final Analysis

Date: *7/4/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	11:48 AM	WB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:48 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:48 AM	WB	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor