



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2550**

**Customer**

Facility Name: Village of Laurelwood  
Address: 401 Collingwood Court  
Cranberry Twp, PA 16066

**Sample Collection**

Date: 6/23/25  
Time: 1:41 PM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool

**Sample Final Analysis**

Date: 6/26/25  
Time: 9:00 AM  
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	2/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	300/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	1:41 PM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/23/25	1:41 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	1:41 PM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2550**

**Customer**

Facility Name: Village of Laurelwood  
Address: 401 Collingwood Court  
Cranberry Twp, PA 16066

**Sample Collection**

Date: 6/23/25  
Time: 1:41 PM  
Method: Grab

Matrix: Recreational Water

Source Type: Pool

**Sample Final Analysis**

Date: 6/26/25  
Time: 9:00 AM  
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	2/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	300/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	1:41 PM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/23/25	1:41 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	1:41 PM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)