



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

**Service****Lab# 312****Customer****Facility Name:** UPMC Lemieux Sports Complex**Address:** 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066**Matrix:** Recreational Water**Source Type:** Cold Plunge**Sample Collection****Date:** 12/23/25**Time:** 11:00 AM**Method:** Grab**Sample Final Analysis****Date:** 12/26/25**Time:** 12:00 PM**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/24/25	11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/24/25	11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/23/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/23/25	11:00 AM	JR	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	12/23/25	11:00 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/23/25	11:00 AM	JR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor