



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 499

Customer

Facility Name: Comfort Inn - Connellsville

Address: 325 N. First St.
Connellsville, PA 15424

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 2/9/26

Time: 11:40 AM

Method: Grab

Sample Final Analysis

Date: 2/12/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/10/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/10/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/9/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	2/9/26	11:40 AM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/9/26	11:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/9/26	11:40 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)