



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM

Lab# 407

C1

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Morrow Park*

Address: *5250 Liberty Ave*
 Pittsburgh, PA 15224

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *2/17/26*
Time: *11:04 AM*
Method: *Grab*

Sample Final Analysis

Date: *2/19/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/18/26 10:00 AM	JC	SM 9222G

Total coliforms:	0/100mls	2/100mls	2/18/26 10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26 2:31 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/18/26 11:00 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/17/26 11:04 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/17/26 11:04 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26 11:04 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)