



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2556

Customer

Facility Name: Villas of Woodcreek

Address: 6075 Caledonia Court
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Time: 1:26 PM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	1:26 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	1:26 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	1:26 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2556

Customer

Facility Name: Villas of Woodcreek

Address: 6075 Caledonia Court
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Time: 1:26 PM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	1:26 PM	AF
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/30/25	1:26 PM	AF
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	1:26 PM	AF

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor