



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 008**

**Customer**

**Facility Name:** Allegheny Valley School Ingram

**Address:** 315 W. Prospect Ave.  
Pittsburgh, PA 15205

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 1/29/26

**Time:** 10:00 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 1/31/26

**Time:** 5:30 PM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26	5:17 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26	5:17 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/29/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	1/29/26	10:00 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	1/29/26	10:00 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/29/26	10:00 AM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)