



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 092

Customer

Facility Name: Doubletree Hotel
Address: 101 Doubletree Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 1/28/26
Time: 8:33 AM
Method: Grab

Sample Final Analysis

Date: 1/31/26
Time: 11:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/29/26 | 11:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/29/26 | 11:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/28/26 | 5:00 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|---------------------|----------|-----------------|------------|-----------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 1/29/26 | 1:00 PM | JC | SM 9213C |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 1/28/26 | 8:33 AM | MM | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 1/28/26 | 8:33 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/28/26 | 8:33 AM | MM | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)