



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2516**

**Customer**

**Facility Name:** *Summerset at Frick Park*

**Address:** *1425 Parkview Blvd.*  
*Pittsburgh, PA 15217*

**Matrix:** *Recreational Water*

**Source Type:** *Wading Pool*

**Sample Collection**

**Date:** *7/21/25*

**Time:** *12:10 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/24/25*

**Time:** *10:00 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:00 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	7/21/25	3:07 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	12:10 PM	MB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/21/25	12:10 PM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:10 PM	MB	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2516**

**Customer**

**Facility Name:** *Summerset at Frick Park*

**Address:** *1425 Parkview Blvd.*  
*Pittsburgh, PA 15217*

**Matrix:** *Recreational Water*

**Source Type:** *Wading Pool*

**Sample Collection**

**Date:** *7/21/25*

**Time:** *12:10 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *7/24/25*

**Time:** *10:00 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	9:00 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	7/21/25	3:07 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/21/25	12:10 PM	MB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/21/25	12:10 PM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	12:10 PM	MB	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor