

## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2430

Customer Sample Collection

Facility Name: Ream Date: 7/1/25

Address: 321 Merrimac St. Time: 11:48 AM Method: Grab

Pittsburgh, PA 15211

Matrix: Recreational Water Sample Final Analysis
Date: 7/4/25

Source Type: Shallow End Time: 9:30 AM
Analyst: AS

**Reporting limit** Method **Accredited Analysis** Results **Analyst Incubation Date/Time** SM 9222G Escherichia Coli: Absent Absent 7/2/25 9:10 AM EB Total coliforms: 0/100mls 2/100mls 7/2/25 9:10 AM EΒ SM 9222B Standard plate count: 200/ml 7/1/25 3:25 PM EΒ SM 9215B 0/ml

| Field Analysis | Results  | Reporting limit |        | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 7/1/25 | 11:48 AM  | WB      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 7/1/25 | 11:48 AM  | WB      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/1/25 | 11:48 AM  | WB      | Visual |

## Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2430

Customer Sample Collection

Facility Name: Ream Date: 7/1/25

Address: 321 Merrimac St. Time: 11:48 AM Method: Grab

Pittsburgh, PA 15211

Matrix: Recreational Water Sample Final Analysis
Date: 7/4/25

Source Type: Shallow End Time: 9:30 AM
Analyst: AS

**Reporting limit** Method **Accredited Analysis** Results **Analyst Incubation Date/Time** SM 9222G Escherichia Coli: Absent Absent 7/2/25 9:10 AM EB Total coliforms: 0/100mls 2/100mls 7/2/25 9:10 AM EΒ SM 9222B Standard plate count: 200/ml 7/1/25 3:25 PM EΒ SM 9215B 0/ml

| Field Analysis | Results  | Reporting limit |        | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 7/1/25 | 11:48 AM  | WB      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 7/1/25 | 11:48 AM  | WB      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/1/25 | 11:48 AM  | WB      | Visual |

## Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)