

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-11

Lab ID No. 02-04041

Lab# 377

Grab

Customer Sample Collection

Facility Name: Drury Hotel Date: 7/8/25 Time: 10:15 AM

Address: 745 Grant St. Method: Pittsburgh, PA 15219

Sample Final Analysis Recreational Water 7/11/25 Matrix: Date:

Time: 9:00 AM Source Type: Spa Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: 7/9/25 9:30 AM Absent Absent AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/9/25 9:30 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/8/25 4:30 PM AΗ SM 9215B **Additional Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Fecal Streptococcus 0/100mls 2/100mls 7/9/25 11:00 AM AΗ SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	12:00 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/8/25	12:00 AM	LM	DPD

7/8/25

1 - 2 NTU

Sample comments

Turbidity:

(When exceeding reporting limit pool or spa is unfit)

1 NTU

andre Smith

12:00 AM

LM

Visual

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-11

Lab ID No. 02-04041

Lab# 377

Grab

Customer Sample Collection

Facility Name: Drury Hotel Date: 7/8/25 Time: 10:15 AM

Address: 745 Grant St. Method: Pittsburgh, PA 15219

Sample Final Analysis Recreational Water 7/11/25 Matrix: Date:

Time: 9:00 AM Source Type: Spa Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: 7/9/25 9:30 AM Absent Absent AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/9/25 9:30 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/8/25 4:30 PM AΗ SM 9215B **Additional Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Fecal Streptococcus 0/100mls 2/100mls 7/9/25 11:00 AM AΗ SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/8/25	12:00 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/8/25	12:00 AM	LM	DPD

7/8/25

1 - 2 NTU

Sample comments

Turbidity:

(When exceeding reporting limit pool or spa is unfit)

1 NTU

andre Smith

12:00 AM

LM

Visual

Andre Smith, Lead Supervisor