# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Customer**

| | |
|---|---|
| Facility Name: | Orchard Park |
| Address: | 100 Macintosh Ct. |
| | Cranberry Twp, PA 16066 |
| Matrix: | Recreational Water |
| Source Type: | Pool |

**Sample Collection**

| | |
|---|---|
| Date: | 6/30/25 |
| Time: | 11:52 AM |
| Method: | Grab |

**Sample Final Analysis**

| | |
|---|---|
| Date: | 7/3/25 |
| Time: | 9:30 AM |
| Analyst: | AS |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 9:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 9:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 3:15 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 6/30/25 | 11:52 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 11:52 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 11:52 AM | ZR | Visual |

**Sample comments**

---
Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

### Customer

| | | | Sample Collection | |
|---|---|---|---|---|
| *Facility Name:* | *Orchard Park* | | *Date:* | *6/30/25* |
| | | | *Time:* | 11:52 AM |
| *Address:* | *100 Macintosh Ct.* | | *Method:* | *Grab* |
| | *Cranberry Twp, PA 16066* | | | |
| | | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | | *Date:* | *7/3/25* |
| | | | *Time:* | *9:30 AM* |
| *Source Type:* | *Pool* | | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 9:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 9:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 3:15 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.0  SU | 7.2 - 7.8 SU | 6/30/25 | 11:52 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 11:52 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 11:52 AM | ZR | Visual |

### Sample comments

---

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)