



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 181

## Laboratory Analysis Report

### Customer

Facility Name: Hyatt Regency Airport

Address: 1111 Airport Blvd.  
Pittsburgh, PA 15231

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 12/2/25

Time: 8:15 AM

Method: Grab

### Sample Final Analysis

Date: 12/5/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	12/2/25	8:15 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/2/25	8:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/25	8:15 AM	VH	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor