



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

E-3

Lab# 476

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Comfort Suites	Date:	2/17/26			
Address:	140 Stroehman Dr. Altoona, PA 16601	Time:	3:00 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	2/19/26			
		Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/18/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26	5:25 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	2/17/26	3:00 PM	DNP	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	2/17/26	3:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26	3:00 PM	DNP	Visual

Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor