



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 160

Customer

Facility Name: *Holiday Inn Express*
Address: *810 Highland Meadow Dr.*
Washington, PA 15301

Sample Collection

Date: *8/19/25*
Time: *11:47 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Final Analysis

Date: *8/22/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/20/25	9:20 AM	SL SM 9222G
-------------------	--------	--------	---------	---------	-------------

Total coliforms:	0/100mls	2/100mls	8/20/25	9:20 AM	SL SM 9222B
------------------	----------	----------	---------	---------	-------------

Standard plate count:	0/ml	200/ml	8/19/25	3:30 PM	EB SM 9215B
-----------------------	------	--------	---------	---------	-------------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/20/25	11:15 AM	EB SM 9230C
---------------------	----------	----------	---------	----------	-------------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.4 SU	7.2 - 7.8 SU	8/19/25	11:47 AM	GR DPD
-----	--------	--------------	---------	----------	--------

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/19/25	11:47 AM	GR DPD
-----------	----------	----------------	---------	----------	--------

Turbidity:	1 NTU	1 - 2 NTU	8/19/25	11:47 AM	GR Visual
------------	-------	-----------	---------	----------	-----------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor