

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2553

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Village of Sewickley Hills

Address: 104 Prescott Place

Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/30/25

 Time:
 11:15 AM

Method: Grab

Sample Final Analysis

 Date:
 8/1/25

 Time:
 3:30 PM

 Analyst:
 AS

Accredited Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent SL Absent 7/30/25 4:30 PM SM 9222G Total coliforms: SL 0/100mls 2/100mls 7/30/25 4:30 PM SM 9222B Standard plate count: 0/ml 200/ml 7/30/25 4:50 PM ΕB SM 9215B **Field Analysis Results Reporting limit** Date/Time **Analyst** Method 8.0 SU 7.2 - 7.8 SU VΗ pH: 7/30/25 11:15 AM DPD Chlorine: 3.0 mg/l 1.0 - 5.0 mg/l 7/30/25 11:15 AM VH DPD Turbidity: 1 NTU 1 - 2 NTU 7/30/25 11:15 AM VΗ Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2553

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Village of Sewickley Hills

Address: 104 Prescott Place

Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 7/30/25

 Time:
 11:15 AM

Method: Grab

Sample Final Analysis

 Date:
 8/1/25

 Time:
 3:30 PM

 Analyst:
 AS

Accredited Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent SL Absent 7/30/25 4:30 PM SM 9222G Total coliforms: SL 0/100mls 2/100mls 7/30/25 4:30 PM SM 9222B Standard plate count: 0/ml 200/ml 7/30/25 4:50 PM ΕB SM 9215B **Field Analysis Results Reporting limit** Date/Time **Analyst** Method 8.0 SU 7.2 - 7.8 SU VΗ pH: 7/30/25 11:15 AM DPD Chlorine: 3.0 mg/l 1.0 - 5.0 mg/l 7/30/25 11:15 AM VH DPD Turbidity: 1 NTU 1 - 2 NTU 7/30/25 11:15 AM VΗ Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor