

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name:

Meeder Flats

weeder rais

Address: 1000 Strand Road

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/28/25

Time: 1:20 PM Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/29/25	11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/28/25	1:20 PM	ZR	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:20 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:20 PM	ZR	Visual	

Sample comments

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name:

Meeder Flats

weeder rais

Address: 1000 Strand Road

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/28/25

Time: 1:20 PM Method: Grab

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/29/25	11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/28/25	1:20 PM	ZR	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:20 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:20 PM	ZR	Visual	

Sample comments

andre Smith