



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2000**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *1400 Main @ Southpointe*  
*Address:*      *1400 Main St.*  
*Canonsburg, PA 15317*

**Sample Collection**

*Date:*      *7/1/25*  
*Time:*      *12:26 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      *7/4/25*  
*Time:*      *9:30 AM*  
*Analyst:*      *AS*

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	12:26 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	12:26 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	12:26 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2000**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *1400 Main @ Southpointe*  
*Address:*      *1400 Main St.*  
*Canonsburg, PA 15317*

**Sample Collection**

*Date:*      *7/1/25*  
*Time:*      *12:26 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      *7/4/25*  
*Time:*      *9:30 AM*  
*Analyst:*      *AS*

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	12:26 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	12:26 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	12:26 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor