



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2298

Customer

Facility Name: JCC- Kaufman Park
Address: 261 Rosecrest Drive
Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 7/7/25
Time: 9:08 AM
Method: Grab

Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/8/25 | 9:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/8/25 | 9:30 AM | AH | SM 9222B |
| Standard plate count: | 250/ml | 200/ml | 7/7/25 | 3:51 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/7/25 | 9:08 AM | EH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 9:08 AM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 9:08 AM | EH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2298

Customer

Facility Name: JCC- Kaufman Park
Address: 261 Rosecrest Drive
Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 7/7/25
Time: 9:08 AM
Method: Grab

Sample Final Analysis

Date: 7/10/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/8/25 | 9:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/8/25 | 9:30 AM | AH | SM 9222B |
| Standard plate count: | 250/ml | 200/ml | 7/7/25 | 3:51 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/7/25 | 9:08 AM | EH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 9:08 AM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 9:08 AM | EH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor