



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**W-13**

**Lab# 2086**

**Customer**

**Facility Name:** Centennial Point  
**Address:** 423 Patriot Dr.  
Carnegie, PA 15106

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 7/1/25  
**Time:** 7:24 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/4/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	72/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/1/25	7:24 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/1/25	7:24 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	7:24 AM	AH	Visual

**Sample comments**

\_\_\_\_\_  
Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**W-13**

**Lab# 2086**

**Customer**

**Facility Name:** Centennial Point  
**Address:** 423 Patriot Dr.  
Carnegie, PA 15106

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 7/1/25  
**Time:** 7:24 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/4/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	72/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/1/25	7:24 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/1/25	7:24 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	7:24 AM	AH	Visual

**Sample comments**

\_\_\_\_\_  
Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

\_\_\_\_\_  
Andre Smith, Lead Supervisor