



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 221

Customer

Facility Name: Masonic Village
Address: 1000 Masonic Dr.
Sewickley, PA 15143
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 6/11/25
Time: 11:00 AM
Method: Grab

Sample Final Analysis

Date: 6/13/25
Time: 3:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/11/25	3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	3:33 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	1/100mls	2/100mls	6/11/25	5:00 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/11/25	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 221

Customer

Facility Name: Masonic Village
Address: 1000 Masonic Dr.
Sewickley, PA 15143
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 6/11/25
Time: 11:00 AM
Method: Grab

Sample Final Analysis

Date: 6/13/25
Time: 3:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/11/25	3:15 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	3:15 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/11/25	3:33 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	1/100mls	2/100mls	6/11/25	5:00 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/11/25	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/11/25	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/11/25	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor